



NOTES:

THE PORTION OF THE TRENCH FROM A POINT 6 INCHES BELOW THE BOTTOM OF THE SEWER SERVICE TO A POINT 8 INCHES ABOVE THE TOP OF THE WATER SERVICE SHALL BE #57 OR # 67 CRUSHED STONE PLACED IN 6-INCH LAYERS.

TRENCH REPAIR SHOULD BE IN ACCORDANCE WITH METRO PUBLIC WORKS.

METRO WATER SERVICES

TRENCHES FOR  
PRIVATE SERVICES

NOT TO SCALE | DATE: 8/18/17

DWG. NO. SHEMATIC 13



*Dan B. Scott*

LICENSED DISTRIBUTION OPERATOR

*8/18*

DIRECTOR OF WATER AND SEWERAGE SERVICES